

AT&T rgfry

From: Phil Pritzker [ppritzker@HABITAT.com]
Sent: Wednesday, April 12, 2017 07:55
To: Richard Fry
Subject: Alderman's office 2017-03-10 fire department response

Mr. Fry,

I received a call from the Alderman's office that you were seeking information related to the 3/10/17 issue with the elevators that brought the fire department to the building.

One heat sensor went bad in the elevator machine room at the top of the building. When a sensor goes off, it causes, by design in the event that there really is a fire, all elevators to return to the lobby – which they did.

The CFD arrived between 3:30 and 3:40 pm and checked out the 41st and 42nd floors. Concluding that there was no emergency and no smoke or fire, they left the building.

The elevators were returned to service about 3:45 – 3:50.

phil

Phil Pritzker, CAM

General Manager



THE HABITAT COMPANY*

EXPERIENCE OUR COMMITMENT TO EXCELLENCE

400 E. Randolph Street • Chicago, IL 60601
312.321.0613 • ppritzker@habitat.com • www.400er.com